

Lincoln Park Public Schools

92 Ryerson Road • Lincoln Park, NJ 07035 • www.lincolnparkboe.org
(973) 696-5500 (Phone) • (973) 696-9273 (Fax)

James W. Grube
Superintendent of Schools

Juanita A. Petty
Interim Business Administrator/Board Secretary

September, 2017

Lincoln Park Board of Education
92 Ryerson Road
Lincoln Park, NJ 07035


Attention: Parents, Teachers, Employees

Re: AHERA Three Year Re-Inspection

The Lincoln Park Board of Education would like to inform all parents, teachers and employees that copies of the Asbestos Management Plan are on file in the Board Office and in the main office of each school. These plans are available for your review during normal school hours.

On August 31, 2017, the Lincoln Park Board of Education conducted a AHERA Three Year Re-Inspection of the schools in the district. Observations made during the surveillance indicated no discernible change in the condition of the ACBM (Asbestos Containing Building Material) identified at the subject facility. The asbestos-containing floor tile appeared to be in good condition, exhibiting normal wear. This wear did not appear to render any implementation of the floor tile friable, and is not considered to motivate any response action. Continued implementation of operations and maintenance activities is indicated as an appropriate response action relative to all of the ACBM identified at the facility.

Sincerely,



Juanita A. Petty, RSBA
Interim School Business Administrator

Posted: Lincoln Park Board of Education Office
Lincoln Park Middle School
Lincoln Park Elementary School
Lincoln Park Office of Special Services