



Environmental and Laboratory Services
 90 ½ West Blackwell St., Dover, New Jersey 07801
 (973) 989-0010 P, (973) 989-0156 F

Analytical Results

Date: March 24, 2017
 Client: Lincoln Park BOE
 Address: 92 Ryerson Road
 Lincoln Park, NJ 07035

Project: Elementary School

Sample description: Drinking Water / 1st Draw / DWS4972-1
 Sample location: Room #4
 Sampled by: A. Dizenzo
 Sample date: 03/16/17
 Time: 07:15
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	3.10 µg/L	15 µg/L	03/22/17	17:36	1	2 µg/L

Sample description: Drinking Water / 1st Draw / DWS4972-2
 Sample location: Field Blank
 Sampled by: A. Dizenzo
 Sample date: 03/16/17
 Time: 07:15
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2 µg/L	15 µg/L	03/22/17	17:42	1	2 µg/L

µg/L = micrograms per liter

All testing was done within the required holding time.

I certify that these samples were analyzed in accordance with procedures approved by the New Jersey Department of Environmental Protection.

Susan VanVeen (Forsv)
 Susan VanVeen, Lab Manager
 NJ Laboratory Certification ID # 14013

March 27, 2017
 Date